



## CURB ONLY TYPE B

## NOTES:

- 1. Concrete shall be of class 520-C-2500.
- 2. All gutter flowlines shall be water tested.
- 3. Scoring lines shall be located at 3' intervals.
- 4. Weakened-plane joints shall be constructed at 12' intervals except through driveway and alley aprons.



3-25-04
DATE APPROVED

PUBLIC WORKS DIRECTOR/C.E.

ASSISTANT CITY ENGINEER

CITY OF ORANGE

PUBLIC WORKS DEPARTMENT

STANDARD CURB AND GUTTER FOR ON-SITE PARKING LOTS

STANDARD PLAN No. 128